

## Satellite Accumulation Area Inspection

<u>Violation Code</u>	<u>Description</u>
-----------------------	--------------------

15	No Signage designating the SAA location <i>Label SAA "Satellite Accumulation Area"</i>
----	---

**Hazardous Chemical Waste**

<u>Violation Code</u>	<u>Description</u>
-----------------------	--------------------

001	Hazardous wastes are properly labeled with a Hazardous Waste label.
002	Hazardous wastes are properly described on Hazardous Waste label (e.g.-no chemical formulas, acronyms, etc.).
003	Waste quantities have not exceeded waste accumulation limits of 55 gal/1 qt (p-list) waste.
004	Hazardous waste is stored in proper containers (i.e. no food or water bottles).
005	All hazardous waste containers are sealed (exception when wastes are being added or removed from the container). <i>Containers in the SAA should be tightly sealed at all times. Chemicals should not be stored in, or transferred to, the SAA until reactions are complete. If a reaction is still occurring, or if the potential for pressure building exists, than the chemical should be kept inside a chemical fume hood with a note stating as much.</i>
006	Containers show no signs of leakage or damage.
007	Hazardous waste containers or secondary containment is compatible with the waste (e.g.-Corrosives and halogenated solvents are in non-metal containers; Hydrofluoric acid waste is in plastic).
008	Waste streams have been separated and not mixed together (i.e. hal or non-hal, mixed heavy metals).
010	Hazardous waste containers are in proper secondary containment.
011	Containers of incompatible waste are stored in separate secondary containment.
012	No chemical residue is present on containers or secondary containment.
013	Hazardous waste containers are not overfilled. (i.e. headspace is present)
009	SAA is located at or near the original point of generation and is under the control of the generator (e.g. in the same room, no door separating generation and SAA).
014	SAA location is secured (i.e. room locked and attended).
015	SAA is labeled "Satellite Accumulation Area."
016	SAA is located in an appropriate area (e.g. away from path of egress, not under a safety shower, etc.).
017	SAA is inspected weekly.

**Satellite Accumulation Area Inspection**

**Hazardous Chemical Waste**

Violation Code    Description

---

NO                    No deficiencies found.

---